



MIDWAY CONTRACTING GROUP LLC.

MBE Certified

7413 Duvan Drive, Unit 2A
Tinley Park, IL 60477
Office: 708-342-1200
Fax: 708-342-1202

December 31, 2020

Ms. Lillian Williams
Eastlake Management
2850 S Michigan Ave.
Chicago, IL 60656

RE: Letter of Completion For: Loomis Courts
Northeast Stairwell
1314 W 15th Street
Chicago, IL

Dear Ms. Williams:

Enclosed is a copy of the project documents for the lead stabilization work conducted at the above-referenced address. Lead activities were conducted and completed on December 28, 2020. All loose and failing lead paint in the above referenced work area was stabilized, primed and painted and all horizontal surfaces were thoroughly cleaned for final wipe testing clearance.

Wipe testing clearance was performed by Jacob and Hefner and all samples passed clearance criteria. The final testing report is enclosed in this transmission.

If there are any questions or concerns regarding this report please contact our office. Thank you for the opportunity to work with you on this project.

Respectfully Submitted,

David Sharkey
Vice President



**Illinois Department of
PUBLIC HEALTH**

EHO 157968

LICENSE, PERMIT, CERTIFICATION, REGISTRATION

The person, firm or corporation whose name appears on this certificate has complied with the provisions of the Illinois statutes and/or rules and regulations and is hereby authorized to engage in the activity as indicated below.

**DIVISION OF ENVIRONMENTAL HEALTH
ASBESTOS PROGRAM**

Issued under the authority of
the Illinois Department of
Public Health

5/15/2021

CAT 500

500-0770

**MIDWAY CONTRACTING GROUP, LLC
ASBESTOS CONTRACTOR LICENSE**

THIS LICENSE IS INVALID IF YOUR
INSURANCE CERTIFICATE IS NOT CURRENT

02/28/2020

**MIDWAY CONTRACTING GROUP, LLC
7413 DUVAN DRIVE, UNIT 2A
TINLEY PARK, IL 60477**

The face of this license has a colored background. Printed by Authority of the State of Illinois • P.O. #5518654



**Illinois Department of
PUBLIC HEALTH**

EH0163815

LICENSE, PERMIT, CERTIFICATION, REGISTRATION

The person, firm or corporation whose name appears on this certificate has complied with the provisions of the Illinois statutes and/or rules and regulations and is hereby authorized to engage in the activity as indicated below.

**DIVISION OF ENVIRONMENTAL HEALTH
LEAD PROGRAM**

Issued under the authority of
the Illinois Department of
Public Health

5/31/2021

5317

L-0449

Midway Contracting Group, LLC

**LEAD ABATEMENT
CONTRACTOR LICENSE**

07/15/2020

Midway Contracting Group, LLC

**7413 Duvan Dr, Unit 2A
Tinley Park, IL 60477**

The face of this license has a colored background. Printed by Authority of the State of Illinois • P.O. #5518654



Notice of Commencement Lead Abatement/Mitigation Project

☒ **Original Notice**

☐ **Revision** _____
(Indicate which # item(s) is revised from original)

Project # _____
IDPH USE ONLY

Mail or fax this notice at least **seven calendar days** prior to the commencement of lead abatement or mitigation projects. The postmark or the fax date will be used to determine correct notification time.

TO:
Illinois Department of Public Health
Div. of Environmental Health, Lead Program
525 W. Jefferson St.
Springfield, IL 62761
Phone: 217-782-3517 Fax: 217-557-1188

1. IDPH License Lead Contractor ID#: L-0449
2. IDPH License Lead Contractor Name: Midway Contracting Group, LLC

A licensed lead supervisor shall be on site during all project activities

Name and Address of Lead Abatement/Mitigation Project

3. Name of Building: Loomis Courts
4. Address: 1314 W 15th Street
5. City: Chicago 6. State: IL 7. ZIP: 60608 8. Phone: 773-502-7474
9. Type of Building: ☒ Residence ☐ Day-care ☐ School ☐ Other
10. Property Owner: Eastlake Management 11. Phone: 312-842-5500
11. Owner Address (if different than listed above): 2850 S Michigan Ave, Chicago, IL

ABATEMENT INFORMATION

12. Start Date: 12/28/20 13. Completion Date: 12/29/20
14. Start Time: 8am 15. Completion Time: 4pm
16. Description of Project: LBP Mitigation and Stabilization
17. IDPH Licensed Lead Supervisor ID #: 4317 18. Name: Juan Grijalva
19. Signature of Contractor's Contact Person
(as listed on the license application to the Department)
20. Telephone: 708 - 342 - 1200 21. Fax: 708 - 342 - 1202

All environmental lead samples shall be analyzed by a laboratory accredited by the National Lead Laboratory Accreditation Program (NLLAP)

TRANSMISSION VERIFICATION REPORT

TIME : 12/21/2020 16:24
NAME : MIDWAY CONTRACTING P
FAX : 7083421202
TEL : 7083421200
SER.# : BROM1J333676

DATE, TIME
FAX NO./NAME
DURATION
PAGE(S)
RESULT
MODE

12/21 16:23
IDPH LEAD
00:00:26
01
OK
STANDARD
ECM



State of Illinois
Illinois Department of Public Health

Notice of Commencement Lead Abatement/Mitigation Project

☒ Original Notice

☐ Revision _____
(Indicate which # item(s) is revised from original)

Project # _____

IDPH USE ONLY

Mail or fax this notice at least **seven calendar days** prior to the commencement of lead abatement or mitigation projects. The postmark or the fax date will be used to determine correct notification time.

TO:

Illinois Department of Public Health
Div. of Environmental Health, Lead Program
525 W. Jefferson St.
Springfield, IL 62761
Phone: 217-782-3517 Fax: 217-557-1188

1. IDPH License Lead Contractor ID#: L-0449

2. IDPH License Lead Contractor Name: Midway Contracting Group, LLC

A licensed lead supervisor shall be on site during all project activities

Name and Address of Lead Abatement/Mitigation Project

3. Name of Building: Loomis Courts

4. Address: 1314 W 15th Street

5. City: Chicago 6. State: IL 7. ZIP: 60608 8. Phone: 773-502-7474

9. Type of Building: ☒ Residence ☐ Day-care ☐ School ☐ Other

10. Property Owner: Eastlake Management 11. Phone: 312-842-5500

TRANSMISSION VERIFICATION REPORT

TIME : 12/21/2020 16:28
NAME : MIDWAY CONTRACTING P
FAX : 7083421202
TEL : 7083421200
SER.# : BROM1J333676

DATE, TIME 12/21 16:28
FAX NO./NAME IDPH LEAD
DURATION 00:00:26
PAGE(S) 01
RESULT OK
MODE STANDARD
ECM



State of Illinois
Illinois Department of Public Health

Notice of Commencement Lead Abatement/Mitigation Project

☒ Original Notice

☐ Revision _____

(Indicate which # item(s) is revised from original)

Project # _____

IDPH USE ONLY

Mail or fax this notice at least **seven calendar days** prior to the commencement of lead abatement or mitigation projects. The postmark or the fax date will be used to determine correct notification time.

TO:

Illinois Department of Public Health
Div. of Environmental Health, Lead Program
525 W. Jefferson St.
Springfield, IL 62761
Phone: 217-782-3517 Fax: 217-557-1188

1. IDPH License Lead Contractor ID#: L-0449

2. IDPH License Lead Contractor Name: Midway Contracting Group, LLC

A licensed lead supervisor shall be on site during all project activities

Name and Address of Lead Abatement/Mitigation Project

3. Name of Building: Loomis Courts

4. Address: 1314 W 15th Street

5. City: Chicago

6. State: IL

7. ZIP: 60608

8. Phone: 773-502-7474

9. Type of Building: ☒ Residence

☐ Day-care

☐ School

☐ Other


10. Property Owner: Eastlake Management

11. Phone: 312-842-5500

124 Unit Apartment Building Complex
Loomis Courts Apartments
1314 and 1342 West 15th Street
Chicago, IL 60608




Interior Common Areas (Only Stairways).
Brick Walls and Concrete Support Columns and Beams with LBP. Deteriorated Walls only found in 1314 Building, NE Stairway, 6th Floor.



Interior Apartments. Metal Window Sills and Casings (Original to Building) with Intact LBP.



Interior Apartments. Metal Window Sills and Casings (Original to Building) with mostly Intact LBP (Some metal casings are deteriorated and need stabilized). Drywall and Plaster around windows tested negative for LBP.



Exterior Building. Metal Hallway Fences and Lintels (over Doors and Windows) with Intact LBP.

Midway Contracting Group, LLC.

Daily Construction Log

Project: Coomis Courts Work Authorization #'s _____ Date: 12-28-20
 Job #: 20-143 _____ Day: Monday
 Area: NE Stairway 6th FL _____ Shift Time: 9-5pm
 Supervisor: Pedro Flores _____ OSHA Type: I II III IV

Crew Size: 4 Activity: (circle one) Prep Removal Clean Tear down Other

Estimated man days: _____
 Man days to date: 4
 Man days remaining: _____

Consulting Company: _____
 PM Name: _____
 Who ran OSHA's: _____
 Quantity: _____ Where were samples delivered: _____

Waste Generation

ACM bags generated today: N/A Bags in dumpster: _____
 ACM drums generated today: N/A Drums in dumpster: N/A

Hauler	P/U date	P/U time	type(acm, gd, metal, lead, ballast)	ticket #	WSR #	yds in box

Type of material being removed: TSI VAT Mastic Transite Spray-on CBR Demo Other
 Control methods being used: Regulated area negative pressure containment glovebag other
 Removal methods employed: Wet Solvent Continuous clean-up dismantle whole other
 Indoor/ outdoor weather conditions: Indoors outdoors cold warm hot dry rain snow calm windy
 Will the PEL be exceeded: Yes: Gross removal previous monitoring results other
 No No removal previous monitoring results neg exposure assessment
 Respiratory protection being used: 1/2 mask PAPR Type C Type C p-d None

Filter change and checklist


(check if applicable or put in quantity)
 water filters 5 mic _____
 water filters 25 mic _____
 neg air pads 2
 neg air links 2
 gfi board check: _____
 hose/fitting check: _____
 manometer check: _____
 shower pan check: _____
 critical seals: _____
 poly walls: _____
 signage check: _____
 neg air running: _____

Todays sub, contact and visitor log

Name	Company	Reason for Visit

Narrative Log of Activities

9 AM on Site Safety Meeting
Prepped the stairway for lead scrap
Scraped the walls + Clean up vacuum the area
Paint
Area clean Ready for wipos


 Supervisor Signature

Mon

Job Site Entry/ Exit Log

Midway Contracting Group, LLC

7413 Duval Drive, Unit 2

Tinley Park, IL 60477

Ph. 708-342-1200 Fax. 708-342-1202

Project: Loomis courts

Date: 12-28-20

Area: NE-Stairway 6th fl

Supervisor: Pedro Flores

Name	Company	Time in	Time out	Time in	Time out	Total hours
1 Pedro Flores	MCG	9:00	1:00	1:30	5:00	8
2 Juan Grigalva	MCG	9:00	1:00	1:30	5:00	8
3 Juan Perez	MCG	9:00	1:00	1:30	5:00	8
4 Eder Hernandez	MCG	9:00	1:00	1:30	5:00	8
5		:	:	:	:	
6		:	:	:	:	
7		:	:	:	:	
8		:	:	:	:	
9		:	:	:	:	
10		:	:	:	:	
11		:	:	:	:	
12		:	:	:	:	
13		:	:	:	:	
14		:	:	:	:	
15		:	:	:	:	
16		:	:	:	:	
17		:	:	:	:	
18		:	:	:	:	
19		:	:	:	:	
20		:	:	:	:	
21		:	:	:	:	
22		:	:	:	:	
23		:	:	:	:	
24		:	:	:	:	
25		:	:	:	:	
26		:	:	:	:	
27		:	:	:	:	
28		:	:	:	:	
29		:	:	:	:	
30		:	:	:	:	

Mon

Daily Safety Meeting

Midway Contracting Group, LLC
7413 Duval Drive, Unit 2
Tinley Park, IL 60477
Ph.708-342-1200 Fax. 708-342-1202

Project:	Coomis Courts
Date:	12-28-20
Area:	NE 8th & 1 way 6th fl
Supervisor:	Pedro Flores

check all that apply

Topic

<input type="checkbox"/>	Fall Protection
<input type="checkbox"/>	Electrical hazards
<input type="checkbox"/>	Proper lifting techniques
<input type="checkbox"/>	Horseplay
<input type="checkbox"/>	Proper PPE, hard hats, hearing, etc
<input type="checkbox"/>	Scaffold Safety
<input type="checkbox"/>	Ladder Safety
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	

Topic

<input checked="" type="checkbox"/>	Trip Hazards
<input type="checkbox"/>	Confined Space
<input type="checkbox"/>	Burning, Welding, Firewatch
<input type="checkbox"/>	Back Safety
<input type="checkbox"/>	Power Tools
<input checked="" type="checkbox"/>	Clean up
<input checked="" type="checkbox"/>	Regulated Areas
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	
<input type="checkbox"/>	

Attendees

- 1 Pedro Flores
- 2 Ever Hernandez
- 3 Juan Perez
- 4 Juan Grigalva
- 5 _____
- 6 _____
- 7 _____
- 8 _____
- 9 _____
- 10 _____

- 11 _____
- 12 _____
- 13 _____
- 14 _____
- 15 _____
- 16 _____
- 17 _____
- 18 _____
- 19 _____
- 20 _____

All employees are shall follow proper safety procedures at all times

All employees shall wear proper attire/PPE at all times on MCG projects. These items include but are not limited to: work boots, long pants, sleeved shirts, hard hats, gloves, respirator and safety glasses. All potentially hazardous situations shall be reported immediately to the project supervisor.

Mon

Lead Paint Area Entry/ Exit Log

Midway Contracting Group, LLC

7413 Duvan Drive, Unit 2

Tinley Park, IL 60477

Ph.708-342-1200 Fax. 708-342-1202

Project: <u>Loomis Courts</u>
Date: <u>12-28-20</u>
Area: <u>NE Stairway 8th Fl</u>
Supervisor: <u>Pedro Flores</u>

	Name	Medical	Time in	Time out	Time in	Time out	Filter change
1	Pedro Flores	✓	9:15	12:45	1:40	2:20	✓
2	Juan Grigalosa	✓	9:15	12:45	1:40	2:30	✓
3	Ever Hernandez	✓	9:15	12:45	14:40	2:40	✓
4	Juan Perez	✓	9:15	12:45	1:40	2:40	✓
5			:	:	:	:	
6			:	:	:	:	
7			:	:	:	:	
8			:	:	:	:	
9			:	:	:	:	
10			:	:	:	:	
11			:	:	:	:	
12			:	:	:	:	
13			:	:	:	:	
14			:	:	:	:	
15			:	:	:	:	
16			:	:	:	:	
17			:	:	:	:	
18			:	:	:	:	
19			:	:	:	:	
20			:	:	:	:	
21			:	:	:	:	
22			:	:	:	:	
23			:	:	:	:	
24			:	:	:	:	
25			:	:	:	:	
26			:	:	:	:	
27			:	:	:	:	
28			:	:	:	:	
29			:	:	:	:	
30			:	:	:	:	



MIDWAY CONTRACTING GROUP LLC.

MBE Certified

7413 Duvan Drive, Unit 2A
Tinley Park, IL 60477
Office: 708-342-1200
Fax: 708-342-1202

Request for Clearance Testing

I, Pedro Flores am requesting that clearance sampling be collected for the containment located in: N-E Stair way
6th Floor

Project Name: Loomis Courts

Project Address: 1314 W 18th St

City/ State: Chicago IL

Date of Clearance Requested: 12-28-20

Lead Supervisor Name: Pedro Flores IDPH #: 053728

Lead Supervisor Signature: [Signature]

Risk Assessor/ Lead Inspector Name: _____

Risk Assessor/ Lead Inspector Signature: _____

Risk Assessor/ Lead Inspector: IDPH #: _____



December 31, 2020

Mr. David Sharkey
Midway Contracting Group, LLC
7413 Duvan Drive, Unit 2
Tinley Park, IL 60477

Re: Lead-Based Paint Lead Dust Wipe Results @
Loomis Courts, Northeast Stairwell Between Floors 6 and 7
1314 West 15h Street
Chicago, IL 60608
Project No. G105

Dear Mr. Sharkey,

Attached please find the results of the lead dust wipe sampling Jacob & Hefner Associates, Inc. (Jacob & Hefner) conducted at the above referenced location. Lead dust wipe sampling was performed after the mitigation, priming and cleaning of the effected walls in the northeast stairwell between the 6th and 7th floors at the Loomis Courts Complex located at 1314 West 15th Street in Chicago, Illinois. Sampling was conducted by Jacob & Hefner representative Mr. James Lehnhardt on December 28, 2020. Mr. Lehnhardt is licensed by the Illinois Department of Public Health as a Lead Inspector.

NIOSH Test Method 7082 "Lead by Flame Atomic Absorption Spectroscopy" was used to collect and analyze air and dust wipe samples to support abatement activities conducted by Midway Contracting Group. Atomic Absorption Spectroscopy (AAS) is a spectroanalytical procedure for the quantitative determination of chemical elements using the absorption of optical radiation (light) by free atoms in the gaseous state. AAS is based on absorption of light by free metallic ions. Air samples collected during abatement activities were found to be in compliance with the Permissible Exposure Limits criteria set by the Occupational Safety and Health Administration (OSHA) of 50 micrograms per cubic meter ($\mu\text{g}/\text{m}^3$) for air samples. Dust wipe samples collected following abatement activities were found to be in compliance with the Illinois Department of Public Health (IDPH) clearance criteria of <10 micrograms per square foot (ug/ft^2).

See Table I for air sampling results and Table II for dust wipe sampling results, Attachment A for licenses and accreditations and Attachment B for sample chain of custody documentation and field log of observations.



Table II
Lead Dust Wipe Sample Results
Loomis Courts, Northeast Stairwell Between Floors 6 and 7
1314 West 15th Street
Chicago, IL. 60608
12/28/20

Sample Number	Area Wiped	Lead Dust Result	Description/ Sample Location
JL122820-01	1ft ²	<10 ug/wipe	Blank
JL122820-02	1ft ²	<10 ug/ft ²	6 th Floor Landing on Stair
JL122820-03	1ft ²	<10 ug/ft ²	Stair Between 6th and 7 th Floors on Stair Tread
JL122820-04	1ft ²	<10 ug/ft ²	7 th Floor Landing on Floor

*The clearance criteria for lead in dust established by the Illinois Department of Public Health (IDPH) is 10 micrograms per square foot (µg/ft²).

All lead dust wipe samples collected were found to be in compliance with the standards set by OSHA and IDPH, respectively.

Please feel free to call me directly at 630.652.4680 if you have any questions or require any additional information.

Sincerely,

JACOB & HEFNER ASSOCIATES, INC.

Todd Huffer
Regional Manager – Environmental Health and Safety Services



ATTACHMENT A



**LEAD INSPECTOR
LICENSE**

LEAD ID	ISSUED	EXPIRES
006681	2/25/2020	1/31/2021

James Lehnhardt
15301 Kilpatrick Ave, Apt 4
Oak Forest, IL 60452



ILLINOIS LEAD PROGRAM
Environmental Health

2019



OCCUPATIONAL TRAINING & SUPPLY, INC.

7233 S. Adams Street ♦ Willowbrook, IL 60527 ♦ (630) 655-3900 ♦ www.otssafety.com

Lead Inspector Refresher

Occupational Training & Supply, Inc. certifies that

James Lehnhardt

has successfully completed the Lead Inspector Refresher course and has passed the competency exam with a minimum score of 70%. This course is accredited by the Illinois Department of Public Health in accordance with the Illinois Lead Poisoning Prevention Code.

Course Date: 2/22/2019

Exam Date: 2/22/2019

Expiration Date: 2/22/2022

Certificate Number: LIR1902220605

Katy DeSalvo, Director



ATTACHMENT B

STAT Analysis Corporation

2242 West Harrison St., Suite 200, Chicago, IL 60612-3766

Tel: (312) 733-0551 Fax: (312) 733-2386 STATinfo@STATAnalysis.com

Accreditations: IEPA ELAP 100445; ORELAP IL300001; AIHA-LAP, LLC 101160; NVLAP LabCode 101202-0

December 29, 2020

Jacob & Hefner Associates
1333 Butterfield Rd., Suite 300
Downers Grove, IL 60515
Telephone: (630) 462-4600
Fax:

Analytical Report for STAT Work Order: 20120746 Revision 0

RE: G105, Loomis Courts, NE Stairway, 1314 W. 15th St.

Dear Jacob & Hefner Associates:

STAT Analysis received 4 samples for the referenced project on 12/28/2020 3:30:00 PM. The analytical results are presented in the following report.

All analyses were performed in accordance with methods as referenced on the analytical report. Those analytical results expressed on a dry weight basis are also noted on the analytical report.

All analyses were performed within established holding time criteria, and all Quality Control criteria met AIHA-LAP, LLC (a NLLAP recognized accrediting body), EPA or laboratory specifications except when noted in the Case Narrative or Analytical Report. Sample acceptance criteria has been met unless noted in the Case Narrative or Sample Receipt Checklist. If required, an estimate of uncertainty for the analyses can be provided. Sample results have not been corrected for contamination based on field blank or other analytical blank, unless noted in the case narrative.

Thank you for the opportunity to serve you and I look forward to working with you in the future. If you have any questions regarding the enclosed materials, please contact me at (312) 733-0551.

Sincerely,



Carly Zoladz

Project Manager

The information contained in this report and any attachments is confidential information intended only for the use of the individual or entities named above. The results of this report relate only to the samples as received and tested. If you have received this report in error, please notify us immediately by phone. This report shall not be reproduced, except in its entirety, unless written approval has been obtained from the laboratory. This analytical report shall become property of the Customer upon payment in full. Otherwise, STAT will be under no obligation to support, defend or discuss the analytical report.




STAT Analysis Corporation*2242 West Harrison St., Suite 200, Chicago, IL 60612-3766**Tel: (312) 733-0551 Fax: (312) 733-2386 STATinfo@STATanalysis.com**Accreditation Numbers : IEPA ELAP 100445 ; ORELAP IL300001 ; AIHA-LAP, LLC 101160***Date Reported:** December 29, 2020**ANALYTICAL RESULTS****Date Printed:** December 29, 2020

Client: Jacob & Hefner Associates
Work Order: 20120746 Revision 0
Project: G105, Loomis Courts, NE Stairway, 1314 W. 15th St.

Client ID	Additional Info	Sample ID	Matrix	Lead Result	Units	Qualifier	Analyst	Date Analyzed	Analytical Method
JC122820-01		20120746-001A	Wipe	< 10	µg/wipe		WJL	12/29/2020	N7082M
JC122820-02	1ft ²	20120746-002A	Wipe	< 10	µg/ft ²		WJL	12/29/2020	N7082M
JC122820-03	1ft ²	20120746-003A	Wipe	< 10	µg/ft ²		WJL	12/29/2020	N7082M
JC122820-04	1ft ²	20120746-004A	Wipe	< 10	µg/ft ²		WJL	12/29/2020	N7082M

Reporting limit for wipes is 10 µg/ft² based on area wiped of 1 ft².**Qualifiers:** B - Analyte detected in the associated Method Blank
S - Spike Recovery outside accepted recovery limitsR - RPD outside accepted recovery limits
E - Value above quantitation range
* - Non-accredited parameter

Comments: Results: t-hutter@yale and hutter, com
jlehmann@yale and hutter.com





LiUNA!
Chicagoland
LABORERS'
District Council Training & Apprenticeship Fund

CERTIFICATE OF TRAINING

This is to certify that

PEDRO FLORES

has successfully completed an

**ASBESTOS ABATEMENT SUPERVISOR
REFRESHER TRAINING**

Training Course held

November 12, 2019 - November 12, 2019

and successfully passed the examination with a minimum score of at least 70% on
November 12, 2019.

Training was in accordance with EPA 40CFR 763 & TSCA Title II.

This course is EPA, Illinois Dept. of Public Health and Indiana Dept. of Environmental Management accredited.

To remain valid, this certificate must be renewed by **11/12/2020 12:00:00 AM.**

Certificate # 6225R

Executive Director



Training Director



CERTIFICATE OF TRAINING
Chicagoland Laborers' Training and Apprenticeship Trust Fund

Carol Stromer
630-453-0006

Chicago
773-413-3315

This is to certify that

PEDRO FLORES

has successfully completed an

LEAD SUPERVISOR REFRESHER

Training Course held **March 15, 2018 - March 15, 2018**

and successfully passed the examination with a minimum score of at least 70% on
March 15, 2018.

Training was in compliance with State and Federal Regulations. This course is EPA and Illinois Dept. of Public Health accredited.

To remain valid, this certificate must be renewed by **March 15, 2021.**

Certificate # S1106R

Executive Director

Training Director

Your employer is required under OSHA Standard 1910.134 to ensure that you are medically certified to wear a respirator as part of your job. The following describes the respirator type and use conditions your account administrator assigned you to test for and the physician's evaluation of your ability to wear the respirator based on the information you provided.

MEDICAL CLEARANCE FOR RESPIRATOR USE

Employee Name: Flores, Pedro
Employee ID: Sr
Employer: Midway Contracting Group LLC
Date Tested: 6/7/2020 8:20:52 AM



Respirator Use Conditions

Respirator Profile	Midway Contracting Group LLC		
Respirator Type	Half Face	Temp < 50 F	Yes
Work Effort	Heavy	Temp > 77 F	Yes
Extent of Use	Over 4 hours per day	Permit Required Confined Space	No
Oxygen Deficient	No	Humid Conditions	Yes
Protective Gear	Eye Protection (goggles, faceshield), Head protection (helmet, hard hat, head cover), Skin Protection (apron, coveralls, Tyvek suits), Gloves, Boots, shoe covers	Hyperbaric	No
Toxic Substances	asbestos	High Altitude	No
Work Description	Wrecking of interior building materials which contain asbestos. Working in humid/wet conditions removing asbestos.		

PHYSICIAN'S EVALUATION

No restrictions on respirator use in the use conditions listed above.
Recertify: Within one year
or when there is a change in health or work conditions.

William H. Lohman

William H. Lohman, MD
Reviewing Physician

6/7/2020 8:38:16 AM
Date

May 28, 2020 8:26AM
AMG 111/ADUVON HAZEL CREST
17850 S KEDZIE AVE STE 1100
HAZEL CREST, IL 60429

ADVOCATE OCC HEALTH



No. 9203 P. 2
Laboratory Report
Final
(800) 877-7016
www.acllaboratories.com

Ordering Provider: Veldman, Mark T		Patient Name: Flores, Pedro			
		ACL Patient ID: AARG5522			
		Date of Birth: 03/13/1969		Sex: M	Age: 51y
		Patient Phone #:			
Accession# R66244393 Requisition# 87138677		Collection Date/Time: 05/22/2020 1004			
Test Name	Flag	Result	Ref Range	Units	Lab
LEAD/ZPP, VENOUS					
LEAD, BLOOD		2.4	<=4.9	mcg/dL	
FEP/ZN PROTOPORPHYRN	H	44	<=35	mcg/dL	

MIDWAY CONTRACTING GROUP, LLC

Qualitative Fit Test

1. 5-4-2020
(Date)

2. Pedro Torres
(Employee)

3. Dave Sharkey
(Examiner)

4(a) North
(Respirator Manufacturer)

(b) 1/2 face
(Respirator Model)

(c) Large
(Respirator Size)

5. Irritant Smoke Pass: XX Fail: _____
(Testing Agent)

6. 5-4-21
(Expiration Date)

By signing below, I have read the (MIDWAY) respirator program and have been trained in the proper maintenance and care of a respirator. I also will adhere to the rules and regulations regarding wearing my respirator while working with environmental hazards.

7. Pedro Torres
(Employee Signature)

8. Dave Sharkey
(Examiner Signature)



**ASBESTOS
PROFESSIONAL
LICENSE**

ID NUMBER ISSUED EXPIRES
100 - 08357 2/25/2020 05/15/2021

JUAN C GRIJALVA
1926 S 59TH AVE., APT 1
CICERO, IL 60804

Environmental Health



**LEAD SUPERVISOR
LICENSE**

LEAD ID ISSUED EXPIRES
004317 2/25/2020 3/31/2021

Juan C Grijalva
1926 S 59th Ave
Cicero, IL 60804



ILLINOIS LEAD PROGRAM
Environmental Health



LiUNA!
Chicagoland
LABORERS'
District Council Training & Apprenticeship Fund

CERTIFICATE OF TRAINING

This is to certify that

JUAN C GRIJALVA

has successfully completed an

**ASBESTOS ABATEMENT SUPERVISOR
REFRESHER TRAINING**

Training Course held

December 10, 2019 - December 10, 2019

and successfully passed the examination with a minimum score of at least 70% on
December 10, 2019.

Training was in accordance with EPA 40CFR 763 & TSCA Title II.

This course is EPA, Illinois Dept. of Public Health and Indiana Dept. of Environmental Management accredited.

To remain valid, this certificate must be renewed by **12/10/2020 12:00:00 AM.**
Certificate # 6234R

Executive Director



Training Director



LiUNA!
Chicagoland
LABORERS'
District Council Training & Apprenticeship Fund

CERTIFICATE OF TRAINING

This is to certify that

JUAN C GRIJALVA

has successfully completed an

LEAD ABATEMENT SUPERVISOR REFRESHER

Training Course held **January 16, 2020 - January 16, 2020**

and successfully passed the examination with a minimum score of at least 70% on

January 16, 2020.

Training was in compliance with State and Federal Regulations. This course is EPA and Illinois Dept. of Public Health accredited.

To remain valid, this certificate must be renewed by **1/16/2023 12:00:00 AM.**

Certificate # S1147R

Executive Director



Training Director



Patient Information	Specimen Information	Client Information
GRIJALVA, JUAN C DOB: 11/04/1968 AGE: 51 Gender: M Fasting: N Phone: NG Patient ID: NG	Specimen: WX967253S Requisition: 1525655 Collected: 05/13/2020 / 08:53 CDT Received: 05/14/2020 / 00:17 CDT Reported: 05/15/2020 / 13:13 CDT	Client #: 97519018 MAIL: 992 PILLAR, EDWARD J OCCMED-IL-BEDFORD PARK 5015 W 65TH ST BEDFORD PARK, IL 60638-5701

Test Name	In Range	Out Of Range	Reference Range	Lab
LEAD (VENOUS), OSHA AND ZINC PROTOPORPHYRIN EVALUATION				
ZINC PROTOPORPHYRIN (ZPP)	<20		mcg/dL Industrial Exposure: <100 mcg/dL (Refer to current OSHA regulation for exposure criteria.)	CB
LEAD (VENOUS), OSHA	1		mcg/dL Industrial Exposure: <40 mcg/dL mcg/dL = mcg/100g for OSHA (Refer to current governmental regulations for exposure criteria.)	CB

This test was developed and its analytical performance characteristics have been determined by Quest Diagnostics. It has not been cleared or approved by the FDA. This assay has been validated pursuant to the CLIA regulations and is used for clinical purposes. Analysis was performed by Inductively Coupled Plasma Mass Spectrometry (ICPMS)

PERFORMING SITE:

CB QUEST DIAGNOSTICS WOOD DALE, 1355 MITTEL BOULEVARD, WOOD DALE, IL 60191-1024 Laboratory Director: ANTHONY V. THOMAS, MD, CLIA: 14D0417052

Your employer is required under OSHA Standard 1910.134 to ensure that you are medically certified to wear a respirator as part of your job. The following describes the respirator type and use conditions your account administrator assigned you to test for and the physician's evaluation of your ability to wear the respirator based on the information you provided.

MEDICAL CLEARANCE FOR RESPIRATOR USE

Employee Name: Grijalva, Juan
Employee ID:
Employer: Midway Contracting Group LLC
Date Tested: 5/12/2020 8:36:07 AM

Respirator Use Conditions

Respirator Profile	Midway Contracting Group LLC	Temp < 50 F	Yes
Respirator Type	Half Face	Temp > 77 F	Yes
Work Effort	Heavy	Permit Required	No
Extent of Use	Over 4 hours per day	Confined Space	Yes
Oxygen Deficient	No	Humid Conditions	No
Protective Gear	Eye Protection (goggles, face shield), Head protection (helmet, hard hat, head cover), Skin Protection (apron, coveralls, Tyvek suits), Gloves, Boots, shoe covers	Hyperbaric	No
Toxic Substances	asbestos	High Altitude	No
Work Description	Wrecking of interior building materials which contain asbestos. Working in humid/wet conditions removing asbestos.		

PHYSICIAN'S EVALUATION

No restrictions on respirator use in the use conditions listed above.
Recertify: Within one year

or when there is a change in health or work conditions.

William H. Lohman, MD

Reviewing Physician

5/12/2020 8:47:19 AM

Date

Damarco Solutions, LLC
1807 Market Blvd #281

MIDWAY CONTRACTING GROUP, LLC

Qualitative Fit Test

1. 2-13-21
(Date)

2. Juan C. Grijalva
(Employee)

3. Dave Sharkey
(Examiner)

4(a) North
(Respirator Manufacturer)

(b) 1/2 face
(Respirator Model)

(c) Large
(Respirator Size)

5. Irritant Smoke
(Testing Agent)

Pass: XX




Fail: _____

6. 2-13-21
(Expiration Date)

By signing below I have read the (MIDWAY) respirator program and have been trained in the proper maintenance and care of a respirator. I also will adhere to the rules and regulations regarding wearing my respirator while working with environmental hazards.

7. 
(Employee Signature)

8. 
(Examiner Signature)




Alteration of this license shall result in legal action
WORKER CERTIFICATE EXPIRES **2/13/2023**

This license issued under authority of the State
of Illinois -Department of Public Health

This license is valid only when accompanied by
a valid training course certificate

If found return to 525 W. Jefferson St., Springfield, IL 62761





LiUNA!
Chicagoland
LABORERS'
District Council Training & Apprentices Fund

CERTIFICATE OF TRAINING

This is to certify that

EVER HERNANDEZ

has successfully completed an

**ASBESTOS ABATEMENT SUPERVISOR
REFRESHER TRAINING**

Training Course held

July 14, 2020 - July 14, 2020

and successfully passed the examination with a minimum score of at least 70% on
July 14, 2020.

Training was in accordance with EPA 40CFR 763 & TSCA Title II.

This course is EPA, Illinois Dept. of Public Health and Indiana Dept. of Environmental Management accredited.

To remain valid, this certificate must be renewed by 7/14/2021 12:00:00 AM.

Certificate # S6379R

Executive Director



5700 W HOMER STREET
CHICAGO IL 60639
773-413-3315

Training Director



LiUNA!
Chicagoland
LABORERS'
District Council Training & Apprentices Fund

CERTIFICATE OF TRAINING

This is to certify that

EVER HERNANDEZ

has successfully completed an

LEAD ABATEMENT WORKER REFRESHER

Training Course held February 13, 2020 - February 13, 2020

and successfully passed the examination with a minimum score of at least 70% on
February 13, 2020.

Training was in compliance with State and Federal Regulations. This course is EPA and Illinois Dept. of Public Health accredited.

To remain valid, this certificate must be renewed by 2/13/2023 12:00:00 AM.

Certificate # 1709R

Executive Director



Training Director

MEDICAL CLEARANCE FOR RESPIRATOR USE



Employee Name: Hernandez, Ever

Employee ID:

Employer: Midway Contracting Group LLC

Date Tested: 6/29/2020 10:07:12 AM

Respirator Use Conditions

Respirator Profile	Midway Contracting Group LLC		
Respirator Type	Half Face	Temp < 50 F	Yes
Work Effort	Heavy	Temp > 77 F	Yes
Extent of Use	Over 4 hours per day	Permit Required Confined Space	No
Oxygen Deficient	No	Humid Conditions	Yes
Protective Gear	Eye Protection (goggles, faceshield), Head protection (helmet, hard hat, head cover), Skin Protection (apron, coveralls, Tyvek suits), Gloves, Boots, shoe covers	Hyperbaric	No
Toxic Substances	asbestos	High Altitude	No
Work Description	Wrecking of interior building materials which contain asbestos. Working in humid/wet conditions removing asbestos.		

PHYSICIAN'S EVALUATION

No restrictions on respirator use in the use conditions listed above.

Recertify: Within one year

or when there is a change in health or work conditions.

William H. Lohman

William H. Lohman, MD

Reviewing Physician

6/29/2020 10:30:05 AM

Date

AMG IL/ADVOH HAZEL CREST
17850 S KEDZIE AVE STE 1100
HAZEL CREST, IL 60429



Laboratory Report Final

(800) 877-7016
www.acllaboratories.com

Ordering Provider: See Accession Level		Patient Name: HERNANDEZ, EVER			
		ACL Patient ID: AAMM4758			
		Date of Birth: 8/15/1994 Sex: M Age: 26Y			
		Patient Phone #: (773) 654-0449			
Accession# R68146655 Requisition# 87160797 Provider: W. ZENEB		Collection Date/Time: 11/07/2020 0945			
Test Name	Flag	Result	Ref Range	Units	Lab
LEAD/ZPP, VENOUS					
LEAD, BLOOD		<2.0	<=4.9	mcg/dL	
FEP/2N PROTOPORPHYRN		33	<=35	mcg/dL	

MIDWAY CONTRACTING GROUP, LLC

Qualitative Fit Test

1. 2.17.2020
(Date)

2. Ever Hernandez
(Employee)

3. Dave Sharkey
(Examiner)

4(a) North
(Respirator Manufacturer)

(b) 1/2 face
(Respirator Model)

(c) Large
(Respirator Size)

5. Irritant Smoke
(Testing Agent)

Pass: XX

Fail:

6. 2.17.2021
(Expiration Date)

By signing below I have read the (MIDWAY) respirator program and have been trained in the proper maintenance and care of a respirator. I also will adhere to the rules and regulations regarding wearing my respirator while working with environmental hazards.

7. 
(Employee Signature)

8. 
(Examiner Signature)



ASBESTOS WORKER LICENSE



LEAD WORKER LICENSE

WORKER ID

057301475

ISSUED

2/21/2020

EXPIRES

2/1/2021

JUAN PEREZ

6425 S KENNETH AVE

CHICAGO, IL 60629



Environmental Health

See Reverse for Endorsements

LEAD ID

1001722

ISSUED

2/19/2020

EXPIRES

3/31/2021

Juan Perez

6425 S Kenneth Ave

Chicago, IL 60629



ILLINOIS LEAD PROGRAM

Environmental Health

Alteration of this license shall result in legal action

WORKER CERTIFICATE EXPIRES 1/13/2022

**This license issued under authority of the State
of Illinois -Department of Public Health**

**This license is valid only when accompanied by
a valid training course certificate**

If found return to 525 W. Jefferson St., Springfield, IL 62761

SWC Institute

Occupational Safety – Environmental Health Training and Consulting

Certificate of Completion

Awarded to

JUAN PEREZ

has successfully completed the 8-hours **Asbestos Abatement Worker Refresher Course**, and has passed the final exam with a score of at least 70%. Training was in accordance with U.S. E.P.A. 40 CFR 763 Subpart E, Appendix C, and Asbestos Containing Materials in Schools: Model Accreditation Plan, TSCA II. Authorized by both AHERA and ASHARA.

ASBESTOS ABATEMENT WORKER REFRESHER COURSE (SPANISH)

Accredited by the State of Illinois Department of Public Health

Course Date: FEB 15, 2020

Exam Date: FEB 15, 2020

Certificate No: AWR0215012020IL

Class Conducted at: 2819 S. Archer Ave. Chicago, Illinois. 60608



Training Director

2020

Expires on: FEB 15, 2021

LEAD PAINT ABATEMENT CERTIFICATE OF COMPLETION

This is to certify that JUAN PEREZ (Spanish) has completed the 1-day EPA model curriculum for lead abatement training for workers recertification based on the Specifications of Lead-Based Paint: HUD Interim Guidelines (6-95); Illinois Department of Public Health, Lead Poisoning Prevention Code 77 ILL ADM Code 845 (2-94); Title X, Housing and Community Development Act (1992); and successfully passed on 01/13/2019 the examination with a minimum score of 70%.

01/13/2019

Course Dates:

01/13/2022

Expires:

190ILWR03

Certificate Number:




PUBLIC HEALTH & SAFETY

Environmental and Occupational Services
37 E. Arlwood Ave., Chicago, IL 60607

www.public-health-safety.com

Office: 312-491-0081
Fax: 312-421-2901



Director of Training

Nicholas J. Penoff

Doctor of Public Health

Phone: 312-491-0081

FORM # L-011ER

Your employer is required under OSHA Standard 1910.134 to ensure that you are medically certified to wear a respirator as part of your job. The following describes the respirator type and use conditions your account administrator assigned you to test for and the physician's evaluation of your ability to wear the respirator based on the information you provided.

MEDICAL CLEARANCE FOR RESPIRATOR USE

Employee Name: Perez, Juan
 Employee ID:
 Employer: Midway Contracting Group LLC
 Date Tested: 5/11/2020 7:07:04 PM

Respirator Use Conditions

Respirator Profile	Midway Contracting Group LLC		
Respirator Type	Half Face	Temp < 50 F	Yes
Work Effort	Heavy	Temp > 77 F	Yes
Extent of Use	Over 4 hours per day	Permit Required Confined Space	No
Oxygen Deficient	No	Humid Conditions	Yes
Protective Gear	Eye Protection (goggles, faceshield), Head protection (helmet, hard hat, head cover), Skin Protection (apron, coveralls, Tyvek suits), Gloves, Boots, shoe covers	Hyperbaric	No
Toxic Substances	asbestos	High Altitude	No
Work Description	Wrecking of interior building materials which contain asbestos. Working in humid/wet conditions removing asbestos.		

PHYSICIAN'S EVALUATION

No restrictions on respirator use in the use conditions listed above.

Recertify: Within one year

or when there is a change in health or work conditions.

William H. Lohman, MD
 Reviewing Physician

5/11/2020 7:14:38 PM
 Date

Damarco Solutions, LLC
 1807 Market Blvd #281

AMG IL/ADVOK HAZEL CREST
 17850 S KEDZIE AVE STE 1100
 HAZEL CREST, IL 60429



Laboratory Report Final

(800) 877-7016
 www.acllaboratories.com

Ordering Provider: Veldman, Mark T		Patient Name: PEREZ, JUAN			
		ACL Patient ID: AAUL2460			
		Date of Birth: 3/3/1978 Sex: M Age: 41Y			
		Patient Phone #:			
Accession# R56227060 Requisition# 86580066		Collection Date/Time: 03/12/2019 1212			
Test Name	Flag	Result	Ref Range	Units	Lab
LEAD/ZPP, VENOUS					
LEAD, BLOOD		3.1	0.0-4.9	mcg/dL	(CL)
LEAD, OSHA		3.1		mcg/100g	(CL)
OCCUPATIONALLY EXPOSED ADULTS (OSHA)					
LOW EXPOSURE:		up to 4.9 MCG/DL			
PERMISSIBLE EXPOSURE:		10 - 42 MCG/DL			
MAXIMUM ALLOWABLE:		53 MCG/DL			
POSSIBLE TOXICITY:		>70 MCG/DL			
PEP/ZN PROTOPORPHYRIN		27		mcg/dL	(CL)
Occupationally Exposed Adults (OSHA)					
Normal: up to 100 mcg/dL					
(CL) = Test Performed at ACL Central Lab WI, 8901 West Lincoln Avenue, West Allis, WI 53227					



MIDWAY CONTRACTING GROUP, LLC

Qualitative Fit Test

1. 2/3/20
(Date)

2. Juan Perez
(Employee)

3. Dave Sharkey
(Examiner)

4(a) North
(Respirator Manufacturer)

(b) 1/2 face
(Respirator Model)

(c) Large
(Respirator Size)

5. Irritant Smoke Pass: XX Fail: _____
(Testing Agent)

6. 2/3/21
(Expiration Date)

By signing below I have read the (MIDWAY) respirator program and have been trained in the proper maintenance and care of a respirator. I also will adhere to the rules and regulations regarding wearing my respirator while working with environmental hazards.

7. Juan Perez
(Employee Signature)

8. Dave Sharkey
(Examiner Signature)